



ACO Polycrete Pty Ltd
185 Briens Road
NORTHMEAD NSW 2152

Attention: Mr Garry Sommerville

RECEIVED
11 JUL 2003

Dear Mr Sommerville

**CERTIFICATE OF PRODUCT APPROVAL
K CHANNEL SYSTEM WITH GALVANISED STEEL RISER AND A
REMOVABLE 38mm GRATE.
K CHANNEL SYSTEM WITH THE STANDARD 123mm GRATE.**

Approval Number ACU-20037/01

Referring to your submission dated 24 June 2003, seeking approval to use the above products in the ACT, I advise that Roads ACT have no objection to the use of these products, as described in your submission documents subject to the following.

- 1- That the above products are quality certified to the relevant Australian Standards.
- 2- That design and construction practice comply with the ACT Department of Urban Services current Design Standards & Specifications for Urban Infrastructure.
- 3- The K Channel with removable 38mm grate to be used only in the access mobility areas.
- 4- Any changes in the product design, materials or method of manufacturing shall necessitate re-submission for authorisation.

Should Developers and contractors wish to use these products they are required to specify them when seeking approval of their engineering design.

Please contact Mr Eddie Kobeissi on (02) 6207 5747 for further inquiries.

Yours sincerely

Jock McLean
Acting Manager Asset Creation
ROADS ACT

7 July 2003

ACT Department of Urban Services • Roads ACT
Level 3, Macarthur House • 12 Wattle Street, Lyneham ACT 2602
Locked Bag 2000 • Civic Square ACT 2608 •
Telephone (02) 6207 6868 • Facsimile (02) 6207 6587
ACT Government Homepage: www.act.gov.au

