

Corporation File No: JT1 2010 10903 V01
Date: 13/09/2011



ACO Polycrete Pty Ltd
33-35 Sorbonne Crescent
Canning Vale WA 6155
Attn: Paul Casey

Dear Paul,

Authorisation No: 11-05-WWA for use of
Solid Top Access Cover and Frame – Class B 945x600 DI/ Class D 970x600 DI
Maintenance Shaft Cover and Frame – Class B DN375/ Class D DN375
in Water Corporation infrastructure

629 Newcastle Street
Leederville 6007
Western Australia

PO Box 100
Leederville 6902
Perth Western Australia

Tel (+61 8) 9420 2420

www.watercorporation.com.au

ABN 28 003 434 917

I am pleased to advise that your ductile iron access covers and frames have been appraised and are conditionally Authorised for general use in Water Corporation infrastructure.

As Authorised Products, they will be registered on the Corporation's Authorised Product and Equipment Register. General use of the above listed products is acceptable, subject to the following conditions:

1. ACO Polycrete Pty Ltd will obtain and maintain product certification for the products to AS/NZS 3996:2006 and WSA PS - 290 by a JAS-ANZ accredited body within 1 calendar year of the date of this letter.
2. Acceptability of the Products shall cease when:
 - the extended term of the product agreement has expired, or
 - any product related default varies beyond the values specified in the Product Agreement Schedule, or
 - any failure to comply with any requirement of the Product Agreement (whether related to currency of the specified Insurances or otherwise) occurs.
 - design or manufacture of the product changes from that submitted.
3. ACO Polycrete Pty Ltd shall provide sufficient printed technical instruction and engineering advisory services to purchasers and installers for the appropriate handling, assembly and use of the Product.
4. ACO Polycrete Pty Ltd, , shall ensure that the products are only installed in accordance with the design limitations previously submitted to Water Corporation.
5. No claim shall be made through advertising or otherwise that the Products have been accepted or tested by the Water Corporation, other than in the terms of this acceptance.

If you have any questions regarding the above, please contact the undersigned.

Yours faithfully

A handwritten signature in black ink, appearing to read "Don McAdie".

Don McAdie
Principal Engineer
Wastewater Conveyance Standards
Water Corporation

